

~~Conventional~~ IN-GROUND SOIL ABSORPTION COMPONENT
MANUAL
FOR PRIVATE ONSITE WASTEWATER SYSTEMS
(VERSION 2.0)
January 30, 2001

State of Wisconsin
Department of Commerce
Division of Safety and Buildings

SBD-~~10567-P (R.6/99)~~ 10705-P (N.01/01)

H:/mjb:In-Ground Soil Absorption Component Manual – w revisions shown.doc (6/19/2001)

TABLE OF CONTENTS

	Page
I. Introduction and Specifications	3
II. Definitions	69
III. Description and Principle of Operation	69
IV. Soil and Site Requirements	811
V. Cover Material	811
VI. Design	811
VII. Site Preparation and Construction	1519
VIII. Operation, Maintenance and Performance Monitoring	2017
IX. References	1922
X. In-ground Worksheet	2023
XI. Example Worksheet	2226
XII. Plan submittal and Installation Inspection	2429

**Published ~~on June 11, 1999~~ by
Dept. of Commerce
Division of Safety and Buildings
Safety and Buildings Publication SBD-~~10567-P (R.6/99)~~10705-P (N.01/01)**

ADA Statement

The Department of Commerce is an equal opportunity service provider and employer. If you need assistance to access services or need material in an alternate format, please contact the Department at (608) 266-3151 or TTY (608) 264-8777.

I. INTRODUCTION AND SPECIFICATIONS

This Private Onsite Wastewater Treatment System (POWTS) component manual provides design, construction, inspection, operation, and maintenance specifications for an in-ground soil absorption component. However, these items must accompany a properly prepared and reviewed plan acceptable to the governing unit to help provide a system that can be installed and function properly. Violations of this manual constitute a violation of chs. Comm 83 and 84, Wis. Adm. Code. The in-ground soil absorption component must receive influent flows and loads less than or equal to those specified in Table 1. When designed, installed and maintained in accordance with this manual, the in-ground soil absorption component provides treatment and dispersal of domestic wastewater in conformance with ch. Comm 83 of the Wis. Adm. Code. Final effluent characteristics will comply with s. Comm 83.43 (8) and 83.44 (2), Wis. Adm. Code when inputs are within the range specified in Tables 1 to 3.

Note: Detailed plans and specifications must be developed and submitted for reviewed and approved by the governing unit having authority over the plan for the installation. Also, a Sanitary Permit must be obtained from the department or governmental unit having jurisdiction. See Section XII for more details.

Table 1 INFLUENT FLOWS AND LOADS	
Design Wastewater flow (DWF)	≤ 5000 gal/day
<u>Dosing of Effluent required when DWF</u>	<u>> 1500 gal/day</u>
Monthly average value of Fats, Oil and Grease (FOG)	≤ 30 mg/L
Monthly average value of five day Biochemical Oxygen demand (BOD ₅)	≤ 220 mg/L
Monthly average value of Total Suspended Solids (TSS)	≤ 150 mg/L
<u>Wastewater particle size</u>	<u>≤ 1/8 inch</u>
Volume of a single dose	≥ 5 times the void volume of the distribution lateral(s) when the system uses pressure distribution
Design wastewater flow (DWF) from one- or two-family dwellings	≥ 150 gal/day/bedroom Based on s. Comm 83.43 (3), (4) or (5), Wis. Adm. Code
Design wastewater flow (DWF) from public facilities	≥ 150% of estimated wastewater flow in accordance with Table 4 of this manual or s. Comm 83.43 (6), Wis. Adm. Code
Wastewater particle size	≤ 1/8 inch

<u>Volume of a single dose to soil absorption component when effluent is delivered to a non-pressure distribution system</u>	<u>≤ 20% of the design wastewater flow</u>
Distribution cell area per orifice when pressurized distribution is used	≤ 6-12 ft ²

Table 2 SIZE AND ORIENTATION	
Minimum area of distribution cell	≥ Design wastewater flow ÷ soil application rate for the most restrictive soil horizon at the infiltrative surface. Soil application rates are listed in s. Comm 83 Tables 83.44-1 or-2, Wis. Adm. Code.
Distribution cell width	≥ 1 foot <u>and ≤ 6 feet</u>
Distribution cell width	≤ 6 feet
Distribution cell depth	≥ 98 inches <u>+ nominal size of distribution pipe</u>
Depth of cover over distribution cell	≥ 12 inches
Depth of cover over distribution cell measured from original grade	≥ 0 inches below original grade
Area of distribution cell	≥ DWF ÷ effluent application rate of the in situ soil at the infiltrative surface

Table 3 OTHER SPECIFICATIONS	
Slope of original grade	≤ 25% in area of component
Vertical separation between distribution cell and seasonal saturation defined by redoximorphic features, groundwater, or bedrock	≥ Equal to depth required by s. Comm 83 Table 83.44-3, Wis. Adm. Code
<u>Bottom of distribution cell</u>	<u>Level</u>
<u>Horizontal separation between distribution cells</u>	<u>≥ 3 feet</u>
Distance between bottom of distribution lateral and in situ soil when aggregate is used	≥ 6 inches
Distance between top of distribution lateral and geotextile fabric when aggregate is used	≥ 2 inches

Distribution cell aggregate material	Meets requirements of s. Comm 84.30 (6) (i), Wis. Adm. Code for stone aggregate
<u>Piping material in the distribution system</u>	<u>Meets requirements of s. Comm 84.30 (2), Wis. Adm. Code</u>
Leaching chamber	Meets requirements of s. Comm 84.30 (6) (h), Wis. Adm. Code.
<u>Geotextile fabric cover over distribution cell when stone is used</u>	<u>Geotextile fabric meeting s. Comm 84.30 (6) (g), Wis. Adm. Code</u>
<u>Slope of gravity flow perforated distribution lateral piping</u>	<u>≤ 4 inches per 100 feet away from distribution boxes, drop boxes or header</u>
<u>Location of gravity flow perforated distribution pipe in distribution cell</u>	<u>Centered in the width of the cell or equally spaced in the width of the cell</u>
<u>Location of leaching chambers in distribution cell</u>	<u>Located as follows:</u> <u>1. Single row of chambers that are in contact with the soil of the distribution cell walls,</u> <u>or</u> <u>2. Multiple rows of chambers that are in contact with each other and have the outside sides in contact with the soil of the distribution cell walls</u>
Length of distribution pipe for components using aggregate and gravity flow distribution	≥ Equal to length of distribution cell minus 6 feet
Distance between distribution lateral pipe end orifice and end of distribution cell for components using aggregate and gravity flow distribution	≤ 3 feet

Table 3
OTHER SPECIFICATIONS
(continued)

<u>Length of leaching chamber row</u>	<u>Chambers extend to end walls of distribution cell</u>
<u>Number of observation pipes per distribution cell</u>	<u>≥ 2</u>
<u>Location of observation pipes</u>	<u>At opposite ends of the distribution cell, and 1/5 to 1/10 the length of the distribution cell measured from the end of the cell</u>
<u>Design and installation of observation pipes installed in stone aggregate</u>	<ol style="list-style-type: none"> <u>1. Have an open bottom</u> <u>2. Have a nominal pipe size of 4 inches</u> <u>3. The lower 6 inches slotted</u> <u>4. Slots are ≥1/4" and ≤ 1/2" in width and located on opposite sides</u> <u>5. Anchored in a manner that will prevent the pipe from being pulled out</u> <u>6. Extend from the infiltrative surface up to or above finish grade</u> <u>7. Terminate with a removable watertight cap, or</u> <u>8. Terminate with a vent cap if ≥ 12 inches above finish grade</u>
<u>Design and installation of observation pipes installed on leaching chambers</u>	<ol style="list-style-type: none"> <u>1. Have an open bottom</u> <u>2. Have a nominal pipe size of 4 inches</u> <u>3. Anchored in a manner that will prevent the pipe from being pulled out</u> <u>4. Extend from a distance ≥ 4 inches above the infiltrative surface through the top of the leaching chamber up to or above finish grade</u> <u>5. Terminate with a removable watertight cap, or</u> <u>6. Terminate with a vent cap if ≥ 12 inches above finish grade</u>

<u>Effluent application to distribution cell</u>	<p>1. <u>If DWF < 1500 gpd, effluent may be applied by gravity flow, dosed to distribution cell or distribution box, then applied to by gravity flow to the distribution cell, or by use of pressure distribution, unless pressure distribution is required in accordance with s. Comm 83.44 (5) (b) Wis. Adm. Code</u></p> <p>2. <u>If DWF ≥ 1500 gpd, effluent must be dosed to distribution cell or distribution box, then applied to by gravity flow to the distribution cell, or by use of pressure distribution, unless pressure distribution is required in accordance with s. Comm 83.44 (5) (b) Wis. Adm. Code</u></p>
Distribution network for pressurized distribution systems Note: Pressure distribution is required when soils or effluent meets parameters of s. 83.44 (5), Wis. Adm. Code.	By use of pressure distribution network conforming with the sizing methods of either Small Scale Waste Management Project publication 9.6, entitled “Design of Pressure Distribution Networks for Septic Tank—Soil Absorption Systems” or Dept. of Commerce publication SBD 10573-P, entitled Pressure Distribution Component Manual for Private Onsite Wastewater Treatment Systems”
<u>Septic tank effluent pump system</u>	<u>Meets requirements of s. Comm 84.10, Wis. Adm. Code</u>
<u>Dosing effluent to leaching chambers</u>	<u>Protection of the infiltrative surface must be provided to prevent erosion at the area where the effluent enters the chamber</u>

<u>Dose tank or compartment volume employing one pump</u>	<p><u>$\geq \text{Volume of a single dose} + \text{reserve capacity}^a + \text{drain back volume}^b + (6 \text{ inches} \times \text{average gal/inch of tank})^c$</u></p> <p><u>Notes: a: Reserve capacity \geq the estimated daily flow.</u></p> <p><u>b: Drain back volume \geq volume of wastewater that will drain into the dose tank from the distribution cell.</u></p> <p><u>c: Four inches of this dimension \geq vertical distance from pump intake to bottom of tank. Two inches of this dimension \geq vertical distance between pump on elevation and high water alarm activation elevation.</u></p>
<u>Dose tank or compartment volume employing duplex pumps</u>	<p><u>$\geq \text{Volume of a single dose} + \text{drain back volume}^a + (6 \text{ inches} \times \text{average gal/inch of tank})^b$</u></p> <p><u>Notes: a: Drain back volume \geq volume of wastewater that will drain into the dose tank from the force main.</u></p> <p><u>B: Four inches of this dimension \geq vertical distance from pump intake to bottom of tank. Two inches of this dimension \geq vertical distance between pump on elevation and high water alarm activation elevation.</u></p>
<u>Siphon tank or compartment volume</u>	<u>\geq What is required to accommodate volumes necessary to provide dosing as specified in this manual</u>
<u>Distribution network for pressurized distribution systems Note: Pressure distribution is required when soils or effluent meets parameters of s. 83.44 (5), Wis. Adm. Code.</u>	<u>By use of pressure distribution network conforming with the sizing methods of either Small Scale Waste Management Project publication 9.6, entitled “Design of Pressure Distribution Networks for Septic Tank – Soil Absorption Systems” or Dept. of Commerce publications SBD-10573-P or SBD-10706-P, entitled Pressure Distribution Component Manual for Private Onsite Wastewater Treatment Systems”.</u>

<u>Vent pipes installed in stone aggregate system</u>	<ol style="list-style-type: none"> 1. <u>Connect to a gravity flow distribution lateral by the use of a fitting</u> 2. <u>Have a nominal pipe size of 4 inches</u> 3. <u>Extend from the distribution lateral > 12 inches above finish grade</u> 4. <u>Terminate in a manner that will allow a free flow of air between the distribution lateral and the atmosphere</u> <p><u>The vent opening port is downward</u></p>
<u>Vent pipes installed on leaching chambers</u>	<ol style="list-style-type: none"> 1. <u>Anchored to the leaching chamber in a manner that will prevent the pipe from being pulled up</u> 2. <u>Have an open bottom</u> 3. <u>Have a nominal pipe size of 4 inches</u> 4. <u>Extend from inside of the leaching chamber > 12 inches above finish grade</u> 5. <u>Terminate in a manner that will allow a free flow of air between the leaching chamber and the atmosphere</u> <p><u>The vent opening port is downward</u></p>
<u>Combination observation/vent pipes installed in a stone aggregate system</u>	<p><u>Meets all of the requirements of observation pipes with the following exceptions:</u></p> <ol style="list-style-type: none"> 1. <u>Have a minimum 4 inch pipe connection to a distribution lateral</u> 2. <u>Connect to the vent pipe at a point above the stone aggregate</u> 3. <u>Extend from the infiltrative surface > 12 inches above finish grade</u> 4. <u>Terminate in a manner that will allow a free flow of air between the distribution lateral and the atmosphere</u> <p><u>The vent opening port is downward</u></p>
<u>Combination observation/vent pipes installed on a leaching chamber</u>	<p><u>Meets all of the requirements of observation pipes with the following exceptions:</u></p> <ol style="list-style-type: none"> 1. <u>Extend from the infiltrative surface ≥ 12 inches above finish grade</u> 2. <u>Terminate in a manner that will allow a free flow of air between the leaching chamber and the atmosphere</u> <p><u>The vent opening port is downward</u></p>
<u>Piping material</u>	<u>Meets requirements of s. Comm 84.30 (2); Wis. Adm. Code for its intended use</u>

Slope of gravity flow perforated distribution lateral piping	≤ 4 inches per 100 feet away from distribution boxes, drop boxes or header
Fabric cover over distribution cell when aggregate is used	Geotextile fabric meeting s. Comm 84.30 (6) (g), Wis. Adm. Code
Horizontal separation between distribution cells	≥ 3 ft.
Bottom of distribution cell	Level
Number of observation pipes per distribution cell	≥ Two extending from distribution cell infiltrative surface to finished grade
Cover material <u>over the geotextile fabric or leaching chamber</u>	Soil that will <u>provide frost protection, prevent erosion and excess precipitation of runoff infiltration and allow air to enter the distribution cell promote plant growth</u>
Erosion and frost protection	Sodded or seeded and mulched
Installation inspection	In accordance with ch. Comm 83, Wis. Adm. Code
Management	In accordance with ch. Comm 83, Wis. Adm. Code and this manual

II. DEFINITIONS.

Definitions not found in this section, are located in ch. Comm 81 of the Wisconsin Administrative Code or the terms use the standard dictionary definition.

A. “Cobbles” means rock fragments greater than 3 inches, but less than 10 inches in diameter.

B. “Septic tank effluent pump system” means a septic tank which has a pump installed in the tank that will pump effluent from the clear zone.

~~B.~~

B.C. “Site plan” means a scaled or completely dimensioned drawing, drafted by hand or computer aided technology, presented in a permanent form that shows the relative locations of setback encumbrances to a regulated object. The site plan also includes a reference to north, the size of the parcel on which the regulated object is placed, and permanent vertical and horizontal reference point or benchmark.

C.D. “Stones” means rock fragments greater than 10 inches in diameter, but less than 24 inches.

III. DESCRIPTION AND PRINCIPLE OF OPERATION.

~~POWTS conventional in-situ~~ In-ground soil component operation is a two-stage process involving both wastewater treatment and dispersal. Treatment is accomplished predominately by physical and biochemical processes within the treatment/dispersal zone. The physical characteristics of the influent wastewater, influent application rate, temperature, and the nature of the receiving soil affect these processes.

Physical entrapment, increased retention time, and conversion of pollutants in the wastewater are important treatment objectives accomplished under unsaturated soil conditions. Pathogens contained in the wastewater are eventually deactivated through filtering, retention, and adsorption by in situ soil.

Dispersal is primarily affected by the depth of the unsaturated receiving soil, the soil's ~~hydraulic~~ conductivity, influent application rate, land slope, and the area available for dispersal.

The in-ground soil absorption component consists of a distribution cell. Influent is discharged to the distribution cell where it flows through the void area formed by stone aggregate and perforated pipe or leaching chambers and then passes into the underlying in situ soil for treatment and dispersal to the environment. The soil, to the prescribed depth, beneath the distribution cell is considered part of the cell known as the treatment/dispersal zone. See Figures 1 & 2.

~~Fill over the distribution cell, consisting of topsoil and subsoil material provides~~ Cover material over the geotextile fabric or leaching chamber is to provide frost protection, prevent erosion protection, a barrier to excess precipitation or runoff infiltration, and allows oxygen transfer. ~~moisture retention sufficient to maintain a good vegetative cover. It must also allow oxygen transfer, so compaction of area should be avoided.~~

The in situ soil within the treatment/dispersal zone provides the physical and biochemical treatment ~~for~~ the influent.




Figure 1 - Cross-section of an in-ground soil absorption ~~conventional~~ component with multiple laterals




Figure 2 - Cross-section of ~~a~~ an in-ground soil absorption ~~conventional~~ component with a single lateral

IV. SOIL AND SITE REQUIREMENTS

Every in-ground soil absorption component design is ultimately matched to the given soil and site.

The design approach presented in this manual is based on criteria that all applied wastewater is successfully transported away from the system, that it will not affect subsequent wastewater additions, ~~and~~ that the effluent is ultimately treated and that reaeration of the infiltrative surface will occur.

A. Minimum Soil Depth Requirements –

The minimum soil factors required for successful in-ground soil absorption component performance are listed in the introduction and specification section of this ~~manual. package.~~

Soil evaluations must be in accordance with ch. Comm 85 of the Wis. Adm. Code. In addition, soil application rates and depth must be in accordance with ch. Comm 83 of the Wis. Adm. Code.

B. Other Site Considerations -

1. In-ground soil absorption component location - In open areas, exposure to sun and wind increases the assistance of evaporation and transpiration in the dispersal of the wastewater.
2. Sites with trees and large boulders - Generally, sites with large trees, numerous smaller trees or large boulders are less desirable for installing an in-ground soil absorption component because of difficulty in preparing the distribution cell area. As with rock fragments, tree roots, stumps and boulders occupy area, thus reducing the amount of soil available for proper treatment. If no other site is available, trees in the distribution cell area must be removed.
3. Setback distances - The setbacks specified in ch. Comm 83, Wis. Adm. Code for soil subsurface treatment/dispersal component apply to in-ground soil absorption components. The distances are measured from the edge of the distribution cell area.

V. COVER MATERIAL

The cover material is of such quality and is placed so that it will not damage either the geotextile fabric or the leaching chambers. Clays are not recommended as they can restrict oxygen transfer. The cover material must not be compacted while being placed since compaction will reduce vegetative growth and oxygen transfer.

VI. DESIGN

~~Every conventional component design is ultimately matched to the given soil and site conditions.~~

~~The design approach presented in this manual is based on the concept that all applied wastewater is successfully transported away from the component so that it will not affect subsequent wastewater additions, and that the effluent is ultimately treated.~~

A. Location, Size and Shape

Placement, sizing and geometry of the component must be in accordance with this manual.

B. Component Design

Design of the component is based upon the DWF and the soil characteristics. It must be sized such that it can accept the daily wastewater flow without causing surface seepage or groundwater pollution. Consequently, the surface area of the treatment and dispersal zone, which is the in situ soil area beneath the component, must be sufficiently large enough to absorb the applied effluent

into the underlying soil. The component must also be designed to avoid encroachment of the water table into the treatment and dispersal zone.

Design of the component includes three major steps, which are: (A) calculating DWF, (B) calculating soil infiltration -area, and (C) design of the distribution cell. Each step is discussed below.

Step A: Design Wastewater Flow Calculations

~~One- and two-family dwellings. Distribution cell size for one- and two-family dwelling application is determined by calculating the design wastewater flow (DWF). To calculate DWF use formula 1.~~

$$\begin{array}{c} \text{Formula 1} \\ \text{DWF} = 150 \text{ gallons/day/bedroom} \end{array}$$

~~One- and two-family dwellings. Distribution cell size for one- and two-family dwelling application is determined by calculating the design wastewater flow (DWF). To calculate DWF use Formulas 1, 2 or 3. Formula 1 is for combined wastewater flows, which consist of blackwater, clearwater and graywater. Formula 2 is for clearwater and graywater only. Formula 3 is for blackwater only.~~

<u>Formula 1</u>	<u>Formula 2</u>	<u>Formula 3</u>
<u>Combined wastewater</u>	<u>Clearwater & Graywater</u>	<u>Blackwater</u>
<u>DWF = 150 gal/day/bedroom</u>	<u>DWF = 90 gal/day/bedroom</u>	<u>DWF = 60 gal/day/bedroom</u>

Public Facilities. Distribution cell size for public facilities application is determined by calculating the DWF using formula 2. ~~Only facilities identified in Public facility estimated daily wastewater flows are listed in Table 4 are included in this manual. Facilities that are not listed in Table 4 are not included in this manual.~~ Estimated dail wastewater flows are determined in accordacnce with Table 4 or s. Comm 83.43 (6), Wis. Adm. Code. Many commercial facilities have high BOD₅, TSS and FOG (fats, oils and grease), which must be pretreated in order to bring their values down to an acceptable range before entering into the at-grade component described in this manual.

$$\begin{array}{c} \text{Formula } \del{24} \\ \text{DWF} = \text{Sum of each } \text{estimated} \text{ wastewater flow per source per day } (\del{\text{from Table 4}}) \times 1.5 \end{array}$$

Where 1.5 = Conversion factor to convert estimated wastewater flow to design wastewater flow

Table 4
Public Facility Wastewater Flows

Source	Unit	Estimated Wastewater Flow (gpd)
Apartment or Condominium	Bedroom	100
Assembly hall (no kitchen)	Person (10 sq. ft./person)	1.3
Bar or cocktail lounge (no meals served)	Patron (10 sq. ft./patron)	4
Bar or cocktail lounge* (w/meals - all paper service)	Patron (10 sq. ft./patron)	8
Beauty salon	Station	90
Bowling alley	Bowling lane	80
Bowling alley (with bar)	Bowling lane	150
Camp, day and night	Person	25
Camp, day use only (no meals served)	Person	10
Campground or Camping Resort	Space, with sewer connection and/or service building	30
Campground sanitary dump station	Camping unit or RV served	25
Catch basin	Basin	65
Church (no kitchen)	Person	2
Church* (with kitchen)	Person	5
Dance hall	Person (10 sq. ft./person)	2
Day care facility (no meals prepared)	Child	12
Day care facility* (with meal preparation)	Child	16
Dining hall* (kitchen waste only without dishwasher and/or food waste grinder)	Meal served	2
Dining hall* (toilet and kitchen waste without dishwasher and/or food waste grinder)	Meal served	5
Dining hall* (toilet and kitchen waste with dishwasher and/or food waste grinder)	Meal served	7
Drive-in restaurant* (all paper service with inside seating)	Patron seating space	10
Drive-in restaurant* (all paper service without inside seating)	Vehicle space	10
Drive-in theater	Vehicle space	3
Employees (total all shifts)	Employee	13
Floor drain (not discharging to catch basin)	Drain	25
Gas station / convenience store	Patron (minimum 500 patrons)	3
Gas station (with service bay)		
Patron	Patron	3
Service bay	Service bay	50
Hospital*	Bed space	135
Hotel, motel or tourist rooming house	Room	65
Medical office building		
Doctors, nurses, medical staff	Person	50
Office personnel	Person	13
Patients	Person	6.5
Migrant labor camp (central bathhouse)	Employee	20

* = May be high strength waste

Table 4
Public Facility Wastewater Flows
(continued)

Source	Unit	Estimated Wastewater Flow (gpd)
Mobile Home (Manufactured home) (served by its own POWTS)	Bedroom	100
Mobile home park	Mobile home site	200
Nursing, Rest Home, Community Based Residential Facility	Bed space	65
Outdoor sport facilities (toilet waste only)	Patron	3.5
Parks (toilets waste only)	Patron (75 patrons/acre)	3.5
Parks (toilets and showers)	Patron (75 patrons/acre)	6.5
Public shower facility	Shower taken	10
Restaurant*, 24-hr. (dishwasher and/or food waste grinder only)	Patron seating space	4
Restaurant*, 24-hr. (kitchen waste only without dishwasher and/or food waste grinder)	Patron seating space	12
Restaurant, 24-hr. (toilet waste)	Patron seating space	28
Restaurant*, 24-hr. (toilet and kitchen waste without dishwasher and/or food waste grinder)	Patron seating space	40
Restaurant*, 24-hr. (toilet and kitchen waste with dishwasher and/or food waste grinder)	Patron seating space	44
Restaurant* (dishwasher and/or food waste grinder only)	Patron seating space	2
Restaurant* (kitchen waste only without dishwasher and/or food waste grinder)	Patron seating space	6
Restaurant (toilet waste)	Patron seating space	14
Restaurant* (toilet and kitchen waste without dishwasher and/or food waste grinder)	Patron seating space	20
Restaurant* (toilet and kitchen waste with dishwasher and/or food waste grinder)	Patron seating space	22
Retail store	Patron (70% of total retail area ÷ 30 sq. ft. per patron)	1
School* (with meals and showers)	Classroom (25 students/classroom)	500
School* (with meals or showers)	Classroom (25 students/classroom)	400
School (without meals or showers)	Classroom (25 students/classroom)	300
Self-service laundry (toilet waste only)	Clothes washer	33
Self-service laundry (with only residential clothes washers)	Clothes washer	200
Swimming pool bathhouse	Patron	6.5

* = May be high strength waste

Step B: Sizing the Distribution Cell Area

The required distribution cell area is based on the DWF and the slowest soil application rate of the in situ soil at the infiltrative surface or lower horizon if the lower horizon adversely affects the dispersal or wastewater in accordance with s. Comm 83.44 (4) (a) and (c), Wis. Adm. Code. Wastewater application rates to the soil are found in ch. Comm 83, Tables 83.44-1 and 83.44-2, Wis. Adm. Code.

Using the above information, the required distribution cell area can be determined using the following formula:

Area = DWF ÷ Lowest application rate of the in situ soil in accordance with s. Comm 83.44 (4) (a) and (c), Wis. Adm. Code. at the infiltrative surface – system elevation. Note: This area may include the area of more than one distribution cell.

Step C: Component Configuration

The maximum distribution cell width is six feet. in accordance with Table 2. The maximum length and width of the distribution cell is dependent on setback requirements of s. Comm Table 83.43-1, Wis. Adm. Code, and soil evaluation results.

Where possible, on sloping sites, the distribution cell is aligned with its longest dimension parallel to the land surface contours as required by the specifications of this package so as not to concentrate the effluent into a small area as it moves vertically and horizontally down slope.

The bottom of the each distribution cell is level so one area of the cell is not overloaded.

Distribution Cell Height

The distribution cell height provides wastewater effluent storage and support of the piping within the distribution cell. The minimum height of the distribution cell, when stone aggregate is used in gravity distribution components is 12 inches or 9 inches when pressure distribution is used. This provides a minimum space of 6 inches beneath the distribution pipe and 2 inches above the distribution piping, as specified in the specification section of this package. See figure 3. The minimum depth of the distribution cell when leaching chambers are used is equal to the height of the leaching chamber. See figure 4.




Figure 3 - Height of system when using aggregate




Figure 4 - Height of system using leaching chambers

Cover Material

A minimum of 12 inches of cover material must be placed over the top of the geotextile fabric or leaching chamber. Finish grade of the cover material must be at or above the surrounding original soil elevation. Depressional areas over the distribution cell that collect and retain surface water runoff must be avoided. It is important that the settled backfill promote runoff by containing no depression areas.

Distribution Network and Dosing Component

The effluent application to the distribution cell may be by gravity or pressure, and may consist of piping or leaching chambers. Distribution boxes or drop boxes may be used to distribute effluent to gravity feed distribution cells. Distribution piping for a gravity component has a nominal inside diameter of 4 inches. The distribution header is non perforated pipe. The slope of gravity flow perforated distribution piping is less than or equal to 4 inches per 100 feet away from distribution boxes, drop boxes or header. When a drop box design is used, the invert of the drop box overflow pipe must be at least 4 inches lower than the invert of the treatment tank outlet or force main connection.

The design and installation of distribution boxes must be watertight and capable of providing a means of providing equal distribution of effluent to each distribution cell. Drop boxes must be watertight and capable of distributing effluent to another distribution cell.

Components that are designed to receive a DWF greater than 1500 gal/day, dose the effluent to the distribution cell by means of a pump or siphon. The dose chamber shall contain sufficient volume to dose the distribution cell as required by its system design, retain drain back volume, contain a one day reserve zone, provide a minimum 2 inch separation between alarm activation and pump-on activation, and allow for protection of the pump from solids.

Drain back volumes can be calculated based on values listed in Table 5.

<u>Table 5</u> <u>VOID VOLUME FOR VARIOUS DIAMETER PIPES</u> <u>BASED ON NOMINAL I.D.^a</u>	
<u>Nominal Pipe Size</u>	<u>Gallons per Foot</u>
<u>1-1/4</u>	<u>0.064</u>
<u>1-1/2</u>	<u>0.092</u>
<u>2</u>	<u>0.163</u>
<u>3</u>	<u>0.367</u>
<u>4</u>	<u>0.65</u>
<u>6</u>	<u>1.469</u>

Note a: Table is based on - $\pi(d/2)^2 \times 12''/\text{ft} \div 231 \text{ cu.in./cu.ft.}$
Where: d = nominal pipe size in inches

A reserve capacity is required on a system with only one pump. The reserve volume must be equal to or greater than the estimated daily wastewater flow. Reserve capacity may be calculated using 100 gallons per bedroom per day for one and two family residences or the values computed by using Table 4.

The dose volume shall be included in the sizing of the dose chamber. (Volume of a septic tank effluent pump system is determined by department plumbing product approval.)

The pump alarm activation point must be at least 2 inches above the pump activation point.

Allow “dead” space below the pump intake to permit settling of solids in the dose chamber. This can be accomplished by placing the pump on concrete blocks or other material that can form a pedestal.

The pump manufacturer’s requirements shall be followed. This may include the “pump off” switch being located high enough to allow for complete immersion of the pump in the dose chamber.

Leaching chamber tops are at or below the original grade. Leaching chambers are placed directly on the bottom of the distribution cell. The location of leaching chambers are in accordance with Table 3 of this manual. If the distribution cell has more than one row of chambers the rows are side by side and in contact with each other.

Observation pipes are installed in the distribution cells and are provided with a means of anchoring to prevent them from being lifted up. Observation pipes extend from the infiltrative surface for stone aggregate systems or from the inside of leaching chambers to a point or on each leaching chamber row and extend to at or above least finish grade and terminate with a waterproof cap. Observation pipes within aggregate distribution cells extend to the bottom of the cell. The portion of the observation pipe below the distribution pipe for stone aggregate systems is slotted while the portion above the distribution pipe is solid wall. is perforated while the portion above the distribution pipe is non perforated. See figure 5. Observation pipes for used on-leaching chamber systems are attached to the chambers in accordance with the chamber manufacturer’s printed instructions, extend from a distance ≥ 4 inches above the infiltrative surface through the top of the leaching chamber up to or above finished grade and terminate with a removable watertight cap. Observation pipes on leaching chambers are non perforated pipe. All observation piping has a nominal inside diameter of 4 inches. See Figure 5.




Figure 5 - Observation pipes

Vent pipes, if installed, connect to the upper half of the gravity flow distribution laterals and extend up to at least 12 inches above finish grade. Vent pipes terminate with the vent opening facing downward by the means of a vent cap or fittings. Vent caps must allow a free flow of air between the distribution lateral and the atmosphere. All vent pipes has a nominal pipe size of 4 inches.

When a vent pipe is connected to an observation pipe, the point of connection shall be made at a point above the stone aggregate for stone aggregate systems and terminate as required for vent pipes.

An observation pipe may serve as a combination observation/vent pipe providing it terminates in the same manner as required for vent pipes. See Figure 6.




Figure 6- Vent and combination observation/vent pipes

VII. SITE PREPARATION AND CONSTRUCTION

Procedures used in the construction of an in-ground a-conventional soil absorption component are just as critical as the design of the component. A good design with poor construction, results in component failure. It is emphasized that the soil only be worked when the moisture content is low to avoid compaction and smearing. Consequently, installations are to be made only when the soil is dry enough to prevent compaction and smearing of the infiltrative surface. The construction plan to be followed includes:

A. Equipment - Proper equipment includes tractors or other equipment that will not compact the infiltrative surface. Minimize foot traffic on infiltrative surface and avoid equipment traffic on or over infiltrative surface.

B. Sanitary Permit - Prior to the construction of the component, a sanitary permit, obtained for the installation must be posted in a clearly visible location on the site. Arrangements for inspection(s) must also be made with the department or governmental unit issuing the sanitary permit.

C. Construction Procedures

1. Check the moisture content and condition of the soil. If the soil at the infiltrative surface can be rolled into a 1/4-inch wire, the site is too wet, smearing and compaction will result, thus reducing the infiltrative capacity of the soil. If the site is too wet, do not proceed until it dries out. If the soil at or below the infiltrative surface is frozen, do not proceed.
2. Set up a construction level or similar device and determine all relative elevations in relationship to the bench mark. It is necessary to determine the bottom elevation of the distribution cell, land surface contour lines, and approximate component elevations critical to the installation.
3. Lay out the absorption area~~(s)~~ within the tested designated area. Where possible lay out the absorption area(s) on the site so that the distribution cell runs parallel with the land surface contours ~~and is within the tested designated area.~~ Reference stakes offset from the corner stakes are recommended in case corner stakes are disturbed during construction.
4. Excavate the distribution cell(s) to the correct bottom elevation(s) taking care not to smear the infiltrative surface. If the infiltrative surface is or side walls are smeared, loosen it with the use of a rake or similar device. The infiltration surface can be left rough and should not be raked smooth.
5. Install observation pipes with the bottom 6 inches of the pipe ~~perforated or~~ slotted for components using stone aggregate. When leaching chambers are installed, the observation pipe connects to the top of the leaching chamber. The observation pipes are located at opposite ends of the distribution cell. Each observation pipe is approximately located at a distance / to 1/10 equal to 1/6 the length of the distribution cell measured from the end of the distribution cell. Installation of the observation pipe includes a suitable means of anchoring the bottom so the pipes are not ~~disturbed-dislodged~~ during inspection.
6. If stone aggregate is used, place it into the excavation until the top of the stone aggregate is at the elevation of the distribution piping ~~component~~. Placement of the stone aggregate is done in such a manner as not to compact the infiltrative surface. If leaching chambers are used, install the leaching chambers in accordance with the manufacturer installation instructions.

7. Place the distribution pipes, as determined from the design, on the stone aggregate. Connect the distribution box, drop box or manifold to the pipe from the treatment or dosing chamber.

8. Install vent pipe, if one is to be installed as prescribed in Table 3.

8.

8.9. If stone aggregate is used place ~~Place~~ stone aggregate over the distribution pipe and the entire distribution cell unit the elevation of the stone aggregate is at least 2 inches above the top of ~~of aggregate over the distribution pipe, and the entire distribution cell.~~

9.10. If stone aggregate is used, place geotextile fabric conforming to requirements of ch. Comm 84, Wis. Adm. Code, over the stone aggregate.

10.11. Place the cover material ~~backfill~~ on top of the geotextile fabric and/or leaching chamber. Avoid backfilling the first 12 inches with cobbles, stones, or frozen material that could damage pipe, chamber or fabric.

VIII. OPERATION, MAINTENANCE AND PERFORMANCE MONITORING

A. The component owner is responsible for the operation and maintenance of the component. The county, department or POWTS service contractor may make periodic inspections of the components, checking for surface discharge, wastewater~~treated effluent levels~~, etc.

The owner or owner's agent is required to submit necessary maintenance reports to the appropriate jurisdiction and/or the department.

B. Design approval and site inspections before, during, and after the construction are accomplished by the county or other appropriate jurisdictions in accordance to ch. Comm 83, Wis. Adm. Code.

C. Routine and preventative maintenance aspects:

1. Treatment and distribution tanks are to be inspected routinely and maintained when necessary in accordance with their approvals.
2. Inspections of the in-ground soil absorption component performance are required at least once every three years. These inspections include checking the liquid levels in the observation pipes and examination for any seepage around the in-ground soil absorptoin component at grade.
3. Winter traffic on the in-ground soil absorption component is not permitted to avoid frost penetration and to minimize compaction.
4. A good water conservation plan within the house or establishment will help assure that the in-ground soil absorption component will not be overloaded.

D. User's Manual: A user's manual is to accompany the component. The manual is to contain the following as a minimum:

1. Diagrams of all component components and their location. This should include the location of the reserve area, if one is provided.
2. Names and phone numbers of local health authority, component manufacturer or POWTS service contractor to be contacted in the event of component failure or malfunction.
3. Information on the periodic maintenance of the component, including electrical/mechanical components.
4. What activities can or cannot occur on the reserve area, if one is provided.

~~5. Notice that the dose chamber, if one is utilized, may fill due to flow continuing during pump malfunction or power outages. One large dose when the power comes on or when the pump is repaired may cause the conventional soil absorption component to have problems. In this situation, the pump chamber should be pumped by a licensed pumper before pump cycling begins or other measures shall be used to dose the conventional soil absorption component with only the proper amount of influent. This may include manual operation of the pump controls until such time the pump chamber has reached its normal level.~~

E. Performance monitoring must be performed on components installed under this manual.

1. The frequency of monitoring must be:
 - a. At least once every three years following installation , and
 - b. At time of a problem, complaint, or failure.
2. The minimum criteria addressed in performance monitoring of components are:
 - a. Type of use,
 - b. Age of component,
 - c. Type of component, dosed or gravity feed,
 - d. Nuisance factors, such as odors or user complaints,
 - e. Mechanical malfunction within the component including problems with valves or other mechanical or plumbing components,

- f. Material fatigue or failure, including durability or corrosion as related to construction or structural design,
 - g. Neglect or improper use, such as overloading the design rate, poor maintenance of vegetative cover, inappropriate cover over the component, or inappropriate activity over the component,
 - h. Pretreatment component maintenance, including dosing frequency, structural integrity, groundwater intrusion or improper sizing,
 - i. Pump or siphon chamber maintenance, including improper maintenance, infiltration, structural problems, or improper sizing,
 - j. Ponding in distribution cell, prior to the pump cycle, ~~is evidence of development of a clogging mat or reduced infiltration rates.~~
 - k. Siphon or pump malfunction including dosing volume problems, breakdown, burnout, or cycling problems, and
 - l. Overflow/seepage problems, as shown by evident or confirmed sewage effluent, including backup.
3. Reports are to be submitted in accordance to ch. Comm 83, Wis. Adm. Code.

IX. REFERENCES

R.J. Otis, G.D. Plews and D.H. Patterson. "Design of Conventional Soil Absorption Trenches and Beds." In: Home Sewage Treatment, Proceeding of the Second National Home Sewage Treatment Symposium, ASAE Publication 5-77.

United States EPA, EPA 625/1-80-012, October 1980. "Design Manual – Onsite Wastewater Treatment and Disposal Systems."

X. IN-GROUND SOIL ABSORPTION COMPONENT WORKSHEET

IN-GROUND SOIL ABSORPTION COMPONENT WORKSHEET

A. SITE CONDITIONS

Evaluate the site and soils report for the following:

- Surface water movement.
- Measure elevations and distances on the site so that slope, contours and available areas can be determined.
- Description of several soil profiles where the system will be located.
- Determine the limiting conditions such as bedrock, high groundwater level, soil permeability, and setbacks.

Slope - ____%

Occupancy: One- or Two-family Dwelling ~~;~~ ____ (# of bedrooms) ~~_____~~

~~_____~~ Public Facility ____ gal/day (Estimated Wastewater flow)

Depth to limiting factor - ____ inches

Minimum depth of unsaturated soil required by Table 83.44-3, Wis. Adm. Code - ____ inches

~~In situ~~ s Soil application rate used - ____ gal/ft²/day

FOG value of effluent applied to component - ____ mg/L

BOD5 value of effluent applied to component - ____ mg/L

TSS value of effluent applied to component - ____ mg/L

Fecal Coliform monthly geometric mean value of effluent applied to component > 104 cfu/100ml – Yes No

Type of distribution cell - ____ Stone aggregate or ____ Leaching chamber

B. DESIGN WASTEWATER FLOW (DWF)

One- or Two-family Dwelling.

Combined wastewater Dwelling.

DWF = 150 gal/day/bedroom x # of bedrooms

= 150 gal/day/bedroom x ____ # of bedrooms

= ____ gal/day

Clearwater and graywater only:

DWF = 90 gal/day/bedroom x # of bedrooms

= 90 gal/day/bedroom x # of bedrooms

= gal/day

Blackwater only:

DWF = 60 gal/day/bedroom x # of bedrooms

= 60 gal/day/bedroom x # of bedrooms

= gal/day

Public Facilities.

DWF = ~~Sum of each Estimated~~ wastewater flow ~~per source per day~~ x 1.5

= gal/day x 1.5

= gal/day

C. WIDTH AND LENGTH OF THE DISTRIBUTION CELL.

1. Determine the design loading rate (DLR) for the site.

From Table 83.44-1 or-2, Wis. Adm. Code, select the ~~effluent soil~~ application rate for the most restrictive soil horizon ~~at the infiltrative surface or a lower horizon if a lower horizon adversely affects the dispersal of wastewater in accordance with s. Comm 83.44 (4) (a) and (c), Wis. Adm. Code. The design loading rate (DLR) is the soil application rate selected from Table 83.44-1 or -2, Wis. Adm. Code., unless the component consists of products that have been recognized through s. Comm 84.50, Wis. Adm. Code, as having a different soil application rate. in contact with the distribution cell that matches the soil conditions. The effluent application rate selected from Table 83.44-1 or -2, Wis. Adm. Code, is the design loading rate (DLR) for the site.~~

DLR = _____ gpd/ft²

2. Determine the distribution cell area.

Calculate the distribution cell area by dividing the daily design wastewater flow (DWF) by the design loading rate (DLR).

$$\text{Distribution cell area} = \text{DWF} \div \text{DLR}$$

$$\text{Distribution cell area} = \text{_____ gpd} \div \text{_____ gpd/ft}^2$$

$$\text{Distribution cell area} = \text{_____ ft}^2$$

3. Select a width (A) for the distribution cell. The width of the distribution cell can not exceed 6 feet.

$$A = \text{_____ ft}$$

4. Determine the distribution cell length.

Calculate the distribution cell length (B) by dividing the required distribution area by the distribution cell width (A).

$$B = \text{Distribution cell area} \div A$$

$$B = \text{_____ ft}^2 \div \text{_____ ft}$$

$$B = \text{_____ ft}$$

XI. EXAMPLE WORKSHEET

IN-GROUND SOIL ABSORPTION COMPONENT WORKSHEET

A. SITE CONDITIONS

Evaluate the site and soils report for the following:

- Surface water movement.
- Measure elevations and distances on the site so that slope, contours and available areas can be determined.
- Description of several soil profiles where the system will be located.
- Determine the limiting conditions such as bedrock, high groundwater level, soil permeability, and setbacks.

Slope - ____ %

Occupancy: One- or Two-family Dwelling; - 4 (# of bedrooms) - 4

~~Public Facility~~ - gal/day (Estimated wastewater flow)

Depth to limiting factor - 60 inches

Minimum depth of unsaturated soil required by Table 83.44-3, Wis. Adm. Code - 36 inches

~~In situ s~~ Soil application rate of in situ soil used - 0.8 gal/ft²/day

FOG value of effluent applied to component - 20 mg/L

BOD5 value of effluent applied to component - 180 mg/L

TSS value of effluent applied to component - 120 mg/L

Fecal Coliform monthly geometric mean value of effluent applied to component > 104 cfu/100ml - Yes ~~No~~

Type of distribution cell - X Stone aggregate or Leaching chamber

B. DESIGN WASTEWATER FLOW (DWF)

One- or Two-family Dwelling.

$$\begin{aligned}\text{DWF} &= 150 \text{ gal/day/bedroom} \times \text{\# of bedrooms} \\ &= 150 \text{ gal/day/bedroom} \times \text{\underline{4}} \text{\# of bedrooms} \\ &= \text{\underline{600}} \text{ gal/day}\end{aligned}$$

Clearwater and graywater only:

DWF = 90 gal/day/bedroom x # of bedrooms

= 90 gal/day/bedroom x # of bedrooms

= gal/day

Blackwater only:

DWF = 60 gal/day/bedroom x # of bedrooms

= 60 gal/day/bedroom x # of bedrooms

= gal/day

Public Facility.

DWF = Sum of each wastewater flow per source per day x 1.5

= gal/day x 1.5

= gal/day

C. WIDTH AND LENGTH OF THE DISTRIBUTION CELL.

1. Determine the design loading rate (DLR) for the site.

From Table 83.44-1 or-2, Wis. Adm. Code, select the ~~effluent soil~~ application rate for the most restrictive soil horizon at the infiltrative surface or a lower horizon if a lower horizon adversely affects the dispersal of wastewater in accordance with s. Comm 83.44 (4) (a) and (c), Wis. Adm. Code. The design loading rate (DLR) is the soil application rate selected from Table 83.44-1 or -2, Wis. Adm. Code., unless the component consists of products that have been recognized through s. Comm 84.50, Wis. Adm. Code, as having a different soil application rate. ~~in contact with the distribution cell that matches the soil conditions. The effluent application rate selected from Table 83.44-1 or 2, Wis. Adm. Code, is the design loading rate (DLR) for the site.~~

DLR = 0.8 gpd/ft²

2. Determine the distribution cell area.

Calculate the distribution cell area by dividing the daily design wastewater flow (DWF) by the design loading rate (DLR).

$$\text{Distribution cell area} = \text{DWF} \div \text{DLR}$$

$$\text{Distribution cell area} = \underline{600} \text{ gpd} \div \underline{0.8} \text{ gpd/ft}^2$$

$$\text{Distribution cell area} = \underline{750} \text{ ft}^2$$

3. Select a width (A) for the distribution cell. The width of the distribution cell ~~can not~~ exceed 6 feet.

$$A = \underline{6} \text{ ft}$$

4. Determine the distribution cell length.

Calculate the distribution cell length (B) by dividing the required distribution area by the distribution cell width (A).

$$B = \text{Distribution cell area} \div A$$

$$B = \underline{750} \text{ ft}^2 \div \underline{6} \text{ ft}$$

$$B = \underline{125} \text{ ft}$$

XII. PLAN SUBMITTAL AND INSTALLATION INSPECTION

A. Plan Submittal

In order to install a system correctly, it is important to develop plans that will be used to install the system correctly the first time. The following checklist may be used when preparing plans for review. The checklist is intended to be a **general guide**. Not all needed information may be included in this list. Some of the information listed may not be required to be submitted due to the design of the system. Conformance to the list is not a guarantee of plan approval. Additional information may be needed or requested to address unusual or unique characteristics of a particular project. Contact the reviewing agent for specific plan submittal requirements, which the agency may require that are different than the list included in this manual.

General Submittal Information

- Photocopies of soil reports forms, plans, and other documents are acceptable. However, an original signature is required on certain documents.
- Submittal of additional information requested during plan review or and questions concerning a specific plan must be referenced to the Plan Identification indicator assigned to that plan by the reviewing agency.
- Plans or documents must be permanent copies or originals.

Forms and Fees

- Application form for submittal, provided by reviewing agency along with proper fees set by reviewing agent.

~~—Onsite verification report signed by the county or appropriated state official.~~

Soils information

- Complete Soils and Site Evaluation Report (form # SBD-8330) for each backhoe pit described; signed and dated by a certified soil tester, with license number.
- Separate sheet showing the location of all borings. The location of all borings and backhoe pits must be able to be identified on the plot plan.

Documentation

- Architects, engineers or designers must sign, seal and date each page of the submittal or provide an index page, which is signed, sealed and dated.
- Master Plumbers must sign, date and include their license number on each page of the submittal or provide an index page, which is signed, sealed and dated.
- Three completed sets of plans and specifications (clear, permanent and legible); submittals must be on paper measuring at least 8-1/2 by 11 inches.
- Designs that are based on department approved component manual(s) must include reference to the manual by name, publication number and publication date.

Plot Plan

- Dimensioned plans or plans drawn to scale (scale indicated on plans) with parcel size or all property boundaries clearly marked.
- Slope directions and percent in system area.
- Benchmark and north arrow.
- Setbacks indicated as per appropriate code.
- Two-foot contours or other appropriate contour interval within the system area. ~~to 25ft. on all sides of system area or include elevations at all four corners of proposed system.~~
- Location information; legal description of parcel must be noted.
- Location of any nearby existing system or well.

Plan View

- Dimensions for distribution cell(s).
- Location of and observation pipes and vent pipes.
- Pipe lateral layout, which must include the number of laterals, pipe material, diameter and length; and number, location and size of orifices.
- Distribution boxes, drop boxes, manifold and force main locations, with materials, length and diameter of all pipes.

Cross Section of System

- Lateral elevation, position of observation pipes, dimensions of distribution cell, and depths of aggregate, and type of cover material such as geotextile fabric, and depth, if applicable.
- Distribution cell details. Dimensions and depths of aggregate.
- Minimum and maximum depths of top of the distribution cell or chamber piping below original and final grades.

~~—Minimum and maximum depths of the excavation from original grade.~~

System Sizing

- For one- and two-family dwellings the number of bedrooms must be included.
- For public buildings, the sizing calculations must be included.

Treatment tank, Dose tank and Pump / Siphon Information

~~—All construction details for site-constructed tanks.~~

- Cross-section and all construction details for site-constructed tanks.
- Size, model and manufacturer information for prefabricated tanks.
- Notation of pump or siphon model, pump performance curve, friction loss for force main and calculation for total dynamic head.

- Cross section of tank / chamber to include storage volumes; connections for piping, vents, and ~~power; electricity;~~ pump “off” setting; dosing cycle and volume; highwater alarm setting, and storage volume above the highwater alarm; and location of vent and manhole.
- Cross section of two compartments tanks or tanks installed in a series must include information listed above.

B. Inspections

Inspection shall be made in accordance with ch. 145.20, Wis. Stats and s. Comm 83.26, Wis. Adm. Code. The inspection form on the following two pages may be used. The inspection of the system installation and/or plans is to verify that the system at least conforms to specifications listed in Tables 1- - 3 of this manual.

POWTS INSPECTION REPORT

(ATTACH TO PERMIT)

GENERAL INFORMATION

Permit Holder's Name	<input type="checkbox"/> City <input type="checkbox"/> Village <input type="checkbox"/> Town of	County	Sanitary Permit No.
State Plan ID No.	Tax Parcel No.	Property Address if Available	

TANK INFORMATION			SETBACKS				
TYPE	MANUFACTURER	CAPACITY	P/L	WELL	BLDG.	VENT TO AIR INTAKE	ROAD
SEPTIC							
DOSING							
AERATION							
HOLDING							

PUMP / SIPHON INFORMATION

Manufacturer:	Model No.	Demand in GPM	Vert. Lift
---------------	-----------	---------------	------------

FORCE MAIN INFORMATION			FRICTION LOSS		
Length	Diameter	Dist. To Well	Component Head	TDH - As Built	TDH - Design

SOIL ABSORPTION COMPONENT

TYPE OF COMPONENT				COVER MATERIAL		
Cell Width	Cell Length	Cell Diameter	Cell Depth	Horizontal Separation	Liquid Depth	No. of Cells

LEACHING CHAMBER OR UNIT	Manufacturer	Model No.
--------------------------	--------------	-----------

SETBACK INFO.	Property Line	Bldg.	Well	Lake/Stream
---------------	---------------	-------	------	-------------

DISTRIBUTION COMPONENT / Elevation data on back of form

Header / Manifold		Distribution Pipe(s)			Hole size	Hole Spacing	Obsv. Tubes Inst. & No.
Length	Dia.	Length	Dia.	Spacing			

SOIL COVER

Depth over center of cell:	Depth over edge of cell:	Depth of Topsoil	Seeded / Sodded	Mulched

DEVIATIONS FROM APPROVED PLAN

--	--

DATE OF INST. DIRECTIVE:

DATE OF ENFORCEMENT ORDER:

DATE OF REFERRAL TO LEGAL COUNSEL:

COMMENTS (Persons present, discrepancies, etc.)

--

COMPONENTS NOT INSPECTED

--

Plan Revision Required <input type="checkbox"/> Yes <input type="checkbox"/> No	Date:	Signature of Inspector:	Cert. Number
--	-------	-------------------------	--------------

Sketch on other side

ELEVATION DATA

Point	Back sight	Height of instrument	Foresight	Elevation	Comments
Bench mark					
Bldg. sewer					
Tank inlet					
Tank outlet					
Tank inlet					
Tank outlet					
Dose tank inlet					
Bottom of dose tank					
Dist. lateral 1					
System elev. 1					
Dist. lateral 2					
System elev. 2					
Dist. lateral 3					
System elev. 3					
Grade elev. 1					
Grade elev. 2					
Grade elev. 3					

SKETCH OF COMPONENT & ADDITIONAL COMMENTS